

PHILIPPINE SPORTS COMMISSION

REQUEST FOR QUOTATION

The Philippine Sports Commission, through its Bids & Awards Committee, invites interested **PHILGEPS-accredited** suppliers to submit signed quotation/s for:

Particular	Quantity				ABC (PHP)	Place of Delivery
	Description	Qty	Unit	Total Cost		
Mechanical and Chemical Descaling of Condenser Tubes of 500TR Super Air and 60TR Water Chiller Including Cooling Tower at Ultra-PhilSports Arena	<p>1 Mechanical and Chemical Descaling of Condenser Tubes of 500TR Super Air and 60TR Water Chiller</p> <p>SCOPE OF WORKS:</p> <ol style="list-style-type: none"> 1. Mobilization 2. Drain water from the heat exchanger units. 3. Check severity of scale by opening condenser unit 4. Return cover then inject descaling chemicals using chemical circulating pump 5. Circulate and soak for at least 16 hours minimum to remove stacked scale inside the unit 6. Opening both side cover of condenser unit to surely remove adhered scale on both end Swab using nylon brush on each condenser tubes 7. Rinse with fresh water to remove chemical residues 8. Return the cover and refill resh water 9. Demobilization and housekeeping <p>***nothing follows***</p> <p>Note: Subject for site inspection at PhilSports Complex, Pasig</p>	1	lot		188,000.00	Property and Supplies Office, PhilSport Complex (Formerly Ultra), Meralco Ave, Pasig City

A copy of PHILGEPS Certification or PHILGEPS Registration and copy of ITR Form must be submitted from May 6 - 9, 2017 10:00 a.m to the Office of the Procurement located at the 2nd Floor Administration Building, Rizal Memorial Sports Complex, Pablo Ocampo Sr. St., Malate, Manila. Quotation may be send by e-mail at pscprocurementoffice@yahoo.com/psccarol.procure@yahoo.com.ph or through facsimile no. 524-3512. For additional information, please contact the Procurement Office nos. 524-35-12, 524-44-08 loc 175.

The Commission reserves the right to not accept any and all quotations or not award the contract on the following grounds:

- There is prima facie evidence of collusion;
- The BAC failed to follow prescribed procurement procedures; and or
- There are justifiable grounds where the contract will not redound to the benefit of the government without incurring any liability to the affected bidder/s.


ATTY. CARLO E. ABARQUEZ
BAC Chairman

4

Date Posted on PHILGEPS & PSC website: May 6, 2017